
Safety-Gram

Title 45, Chapter 11

October 2018

Volume 19, Number 10

FLAMMABLE STORAGE AREA



Section 910.B.1

No person shall smoke or use an open flame where flammable or combustible liquids or greases are stored or in areas or places where fire or explosion hazards exist.

Section 910.B.3

Areas surrounding flammable-liquid storage tanks and electric substations and transformers shall be kept free from dry grass, weeds, underbrush and other combustible materials for at least (25) feet in all directions.



Section 910.B.15

Each mine shall have available, or be provided with, appropriate types of fire-fighting equipment adequate for the size of the mine;

Section 910.B.17 – Fire Extinguishers shall be:

- Adequate in number and size and of the appropriate type for each particular fire hazard involved,
- Replaced immediately with fully charged extinguishers of the same capability after any discharge is made from the extinguishers,
- Tested at least once every twelve (12) months and maintained according to the manufacturer's recommendation. Each extinguisher shall bear a tag showing the date of testing and the name of the person making the examination for testing and
- Approved by Underwriter's Laboratories, Inc. or Factory Mutual Research Corporation.

KEEP IT CLEAN