

Safety-Gram

Title 45, Chapter 11

July 2010

Volume 11, Number 7

OVERHEAD ELECTRICAL LINES



Section 915.39 – Equipment with booms or masts which are not properly protected shall not be operated where the booms or masts can come within ten (10) feet of an energized overhead power line;

Section 915.40 – Overhead high potential power lines shall be installed as specified by the National Electrical Safety Code;

Section 915.41 – When equipment must be moved under energized power lines and the clearance is less than ten (10) feet, the power lines shall be de-energized or other precautions shall be taken.