

---

# Safety-Gram

## Title 45, Chapter 11

---

May 2021

Volume 22, Number 5

### FLAMMABLE STORAGE AREA

#### Section 910.B.3

Areas surrounding flammable-liquid storage tanks and electric substations and transformers shall be kept free from dry grass, weeds, underbrush and other combustible materials for at least (25) feet in all directions.

